

**PROFORMA REGARDING SAFE DRINKING WATER AND
SANITARY CONDITION CERTIFICATE**


No. 2397

Date: 22-05-2025

It is certified that an inspection team headed by Supdt. CHC, Beltikiri, Dhenkanal from CHC Beltikiri, Dhenkanal inspected the Royal International Public School, At- Ranja, Po- Kankadapal, Dhenkanal on date: 17/05/2025 and on the basis of Water Test Report (Attached) bearing no DWTLD-TR- 11 URL dated 22/05/2025 of District Water Testing Laboratory, RWS & S Division Dhenkanal certified that the Royal International Public School, At- Ranja, Po- Kankadapal, Dhenkanal has safe drinking water facilities for the students and staff members of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/ State/ U.T. Government.

The above is valid for a period of 03 Years from issue of this letter.

Signature with Seal: _____


22-5-2025


Name: Dr. Nilamani Dillipchand Behera


Designation: District Public Health Officer, I/c,
DISTRICT PUBLIC HEALTH OFFICER
DHENKANAL Dhenkanal.

To

The Principal
Royal International Public School, Dhenkanal
At-Ranja, Po- Kankadapal,
Dhenkanal, 759013

(Name & Address of the School)


22/05/2025
Manager
Royal International Public School
Dhenkanal


22/05/2025
Principal
Royal International Public School
Ranja, Kankadapal, Dhenkanal

**DISTRICT WATER TESTING LABORATORY****RWS&S DIVISION DHENKANAL**

distlabdhenkanal@gmail.com

**WATER ANALYSIS REPORT.**

TEST REPORT NO.- DWTL-D-TR-11

DATE OF ISSUE - 22.05.2025

ULR NO :-

Sample Particulars				Sample Details		
Name of the of Customer/ Address	ROYAL INTERNATIONAL PUBLIC SCHOOL			Type of Source	Drinking Water	
				Date of Sample Collection	21.05.2025	
				Date of Receipt of Sample	21.05.2025	
				Reference Letter No. / Date	RIPS/2025/050/21.05.2025	
Sample Package Condition :				Date of Sample Registration	21.05.2025	
a) Quantity of Sample Received -1000ml (Each)				Sampling protocol	Sampling is not applicable for this laboratory	
b) Type of Container - PP				Sample Collected by	self	
c) Sealed/unsealed: -Sealed	Sealed			Sample Location	AT-RANJA, PO-KANKADAPAL, DIST-DHENKANAL	
TEST RESULT						
Test Started on		21.05.2025		Test Completed on		22.05.2025
Sl No	Test Parameters	Units	Results	Requirements IS 10500:2012		Test Method
				Acceptable Limit (Maximum limit)	Permissible Limit (Maximum Limit)	
1	Temperature	°C	25.5	-----	-----	APHA 24th Ed. 2023: 2550 B (Laboratory and Field Method)
2	pH	pH Unit	7.24	6.5 -- 8.5	No relaxation	APHA 24th Ed. 2023: 4500 H+ B (Electrometric Method)
3	Turbidity	NTU	0.70	1	5	APHA 24th Ed. 2023: 2130 B (Nephelometric Method)
4	Electrical Conductivity (EC)	uS/cm	268	-----	-----	APHA 24th Ed. 2023: 2510 B (Laboratory Method)
5	Total Dissolved Solids (TDS)	mg/l	174	500	2000	APHA 24th Ed. 2023: 2540 C (Total Dissolved Solids Dried at 180°C)
6	Iron (as Fe)	mg/l	0.22	1.0	No relaxation	APHA 24th Ed. 2023: 3500-Fe B (Phenanthroline Method)
7	Colour	Hazen	1.00	5.00	15.00	APHA 24th Ed. 2023 : 2120 B (Visual Comparison Method)
8	Odour	Qualitative Observation	Agreeable	Agreeable	Agreeable	APHA 24th Ed. 2023:2150 B (Threshold Odour Test)
9	Taste	Qualitative Observation	Agreeable	Agreeable	Agreeable	APHA 24th Ed.2023 : 2160 B(Flavour Threshold Test)
10	Total Alkalinity (as CaCO ₃)	mg/l	76	200	600	APHA 24th Ed.2023: 2320 B (Titration Method)
11	Chloride (as Cl)	mg/l	16	250	1000	APHA 24th Ed. 2023: 4500 Cl- B (Argentometric Method)
12	Total Hardness (as CaCO ₃)	mg/l	60	200	600	APHA 24th Ed.2023: 2340 C (EDTA Titrimetric Method)
13	Fluoride	mg/l	0.18	0.5	1.5	Ion Selective method(APHA 4500F)
14	Total Coli form	MPN	Nil	Shall not be detected in any/100 ml	No relaxation	MPN method(APHA-9221B)

Information on Test Report:

Result relates only to samples received in the Laboratory

The test reports shall not be reproduced except in full without written approval of DWTL

Sample will be discard after 15 days of analysis.

Checked and Reviewed by

Junior Laboratory Assistant
District Water Testing Laboratory
DhenkanalNeerajoti Mohanty
Manager
Royal International Public School
Dhenkanal

*****End of Report*****

Principal
Royal International Public School
Ranja, Kankadpal, DhenkanalAssistant Executive Engineer
RWS&S Sub-Division, Dhenkanal
R.W.S & S Sub-Division
Dhenkanal